

**From:** "Bray, Chris" <Chris.Bray@UnitedWater.com>  
**To:** Gary Reynolds <Gary.Reynolds@dnr.state.ga.us>  
**Date:** 6/22/2011 11:52 AM  
**Subject:** RE: SSO LS2039 SSI

Gary,

The release occurred when the controller that operates the wet-well pumps malfunctioned and did not allow the pumps to come on when called to run. The SCADA system called out as designed when the wet-well level was high.

-----Original Message-----

From: Gary Reynolds [mailto:Gary.Reynolds@dnr.state.ga.us]  
Sent: Wednesday, June 22, 2011 11:42 AM  
To: Bray, Chris  
Subject: Re: SSO LS2039 SSI

Sounds good, calling a release...could you give a reason as to cause of the back-up overflow?

>>> "Bray, Chris" <Chris.Bray@UnitedWater.com> 6/22/2011 10:11 AM >>>  
Mr. Reynolds,

I am writing to inform you of a minor release that occurred at lift station 2039 on SSI yesterday evening around 10:45 p.m. The release was 50 gallons, was contained, and did not reach a waters of the state. The release area was cleaned up with a VAC truck. Please call me at 912.717.3170 if you have any additional questions regarding this matter.

Thank you,

Chris Bray  
Water and Waste Water Supervisor  
Compliance Coordinator  
UNITED WATER  
161 S. Harrington Road  
ST. Simon Island GA 31522  
Ph: 912-261-7160  
Cell; 912-717-3170  
Fax: 912-638-2230

[cid:image001.gif@01C9AC71.028EBA80]<<http://www.unitedwater.com/>>

Making the planet sustainable is the best job on Earth.

TEAMWORK= It is amazing what you can accomplish if you do not care who gets the credit.